

Atlas Tube Alabama
 171 Cleage Dr
 Birmingham, Alabama USA
 35217
 Tel:
 Fax:



REF/B/L: 81103199
 Date: 08/05/2022
 Customer: 1592

MATERIAL TEST REPORT

Sold To
 Superior Supply and Steel
 PO Box 2388
 SULPHUR LA 70664
 USA

Shipped To
 Superior Supply and Steel
 318 North Cities Service Hwy
 SULPHUR LA 70663
 USA

Material: 2.0x2.0x250x20"0"(10x5). **Material No.:** 200202502000
Sales Order: 1814872 **Purchase Order:** PO234390-11
 Heat No C Mn P S Si Al Cu Cb Mo Ni Cr V Ti B N Ca
 22072582 0.200 0.730 0.006 0.002 0.030 0.028 0.090 0.001 0.012 0.040 0.040 0.002 0.000 0.0001 0.0081 0.0020
Bundle No PCS Yield Tensile
 M400210066 50 063771 Psi 081475 Psi
Heat MILL **Mill Location**
 22072582 BIGRIVER Osceola,AR
Material Note:
Sales Or. Note:

Certification
 ASTM A500-21 GRADE B&C
 Pre-Consumer (Post Industrial) 95.00%
 Post Consumer 5.00%
 % Recycled Content 76.00%
 Method EAF
 Tensile 081475 Psi
 Yield 063771 Psi
 Mill Location Osceola,AR

Material: 2.0x2.0x250x20"0"(10x5). **Material No.:** 200202502000
Sales Order: 1814872 **Purchase Order:** PO234390-11
 Heat No C Mn P S Si Al Cu Cb Mo Ni Cr V Ti B N Ca
 2122871 0.210 0.750 0.009 0.003 0.020 0.030 0.070 0.000 0.010 0.030 0.040 0.003 0.002 0.0000 0.0060 0.0020
Bundle No PCS Yield Tensile
 M400210081 50 073011 Psi 079320 Psi
Heat MILL **Mill Location**
 2122871 NUCOR HICKMAN,AR
Material Note:
Sales Or. Note:

Certification
 ASTM A500-21 GRADE B&C
 Pre-Consumer (Post Industrial) 31.80%
 Post Consumer 20.70%
 % Recycled Content 52.50%
 Method EAF
 Tensile 079320 Psi
 Yield 073011 Psi
 Mill Location HICKMAN,AR

Authorized by Quality Assurance *Jason Richard*
Jason Richard

The results reported on this report represent the actual attributes of the material furnished and indicate full compliance with all applicable specification and contract requirements.
 CE calculated using the AWS D1.1 method. This document is in compliance with the requirements of EN 10204 type 3.1

