



CMC STEEL TEXAS  
1 STEEL MILL DRIVE  
SEGUN TX 78155-7510

**CERTIFIED MILL TEST REPORT**  
For additional copies call  
800-227-6489

We hereby certify that the test results presented here  
are accurate and conform to the reported grade specification

Quality Assurance Manager

Rolando A Davila

HEAT NO.: 1080854  
SECTION: ANG 3 X 3x1/4 20'0" A36/52950  
SP49  
GRADE: ASTM A36-19/A529-14 Gr 50  
ROLL DATE: 08/15/2022  
MELT DATE: 06/25/2022  
Cert. No.: 85181133 / 080854A667

S Superior Supply & Steel Co  
O 318 N Cities Service Hwy  
L Sulphur LA  
D US 70663-5424  
US 706252300  
T 3376258509  
O 3376258509

S Superior Steel  
H 217 Darnall Rd  
I New Iberia LA  
P US 70560-0781  
T 8002529017  
O

Delivery#: 85181133  
BOL#: 74998553  
CUST PO#: 236439-11  
CUST P/N:  
DLVRY LBS / HEAT: 4802.000 LB  
DLVRY PCS / HEAT: 49 EA

Characteristic	Value	Characteristic	Value	Characteristic	Value
C	0.14%	Elongation test 1	26%		
Mn	0.63%	Elongation Gage Lgth test 1	8IN		
P	0.012%	Yield to tensile ratio test1	0.76		
S	0.025%	Yield Strength test 2	55.6ksi		
Si	0.15%	Tensile Strength test 2	71.5ksi		
Cu	0.35%	Elongation test 2	25%		
Cr	0.12%	Elongation Gage Lgth test 2	8IN		
Ni	0.11%	Yield to tensile ratio test2	0.78		
Mlo	0.034%				
V	0.003%				
Cb	0.008%				
Sn	0.011%				
B	0.0002%				
Ti	0.001%				
N	0.0099%				
Carbon Eq A6	0.31%				
Carbon Eq A529	0.33%				
Yield Strength test 1	55.3ksi				
Tensile Strength test 1	72.6ksi				

The following is true of the material represented by this MTR:  
 \*Material is fully killed and is Hot Rolled Steel  
 \*100% melted, rolled, and manufactured in the USA  
 \*EN10204:2004 3.1 compliant  
 \*Contains no weld repair  
 \*Contains no Mercury contamination  
 \*Manufactured in accordance with the latest version of the plant quality manual  
 \*Meets the "Buy America" requirements of 23 CFR635.410, 49 CFR 661  
 \*Warning: This product can expose you to chemicals which are known to the State of California to cause cancer, birth defects or other reproductive harm. For more information go to [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)

REMARKS : ALSO MEETS ASTM GRADE A36, A529-50, A572-50, A709-36, A709-50, A992, AASHTO M270-36, M270-50, CSA G40.21-04 44W, 50W