

Atlas Tube Arkansas
 6651 E Hwy 137
 Blytheville Arkansas USA
 72315
 Tel:
 Fax:



REF.B/L: 81077326
 Date: 03/18/2022
 Customer: 1592

MATERIAL TEST REPORT

Material: 4.0x3.0x250x20"0(6x5). **Material No:** 400302502000 **Made in:** USA
Melted and Poured in: USA

Sales Order: 1746974 **Purchase Order:** PO231220-11

Heat No	C	Mn	P	S	Si	Al	Cu	Cb	Mo	Ni	Cr	V	Ti	B	N	Ca
NL6291	0.190	0.840	0.007	0.002	0.023	0.029	0.130	0.001	0.010	0.060	0.050	0.004	0.001	0.0000	0.0060	0.0020

Bundle No M400201232 **PCs** 6 **Yield** 068052 Psi **Tensile** 083355 Psi **Eln.2in** 29 % **Certification** ASTM A500-21 GRADE B&C **CE: 0.36**

Heat	MILL	Mill Location	Method	Recycled Content	Post Consumer	Pre-Consumer (Post Industrial)	% Harvested	Within Miles of Location
NL6291	NUCOR	Decatur,AL	EAF	53.70%	23.80%	29.90%	86%	500

Material Note:
Sales Or. Note:

Material: 4.0x3.0x250x20"0(6x5). **Material No:** 400302502000 **Made in:** USA
Melted and Poured in: USA

Sales Order: 1746974 **Purchase Order:** PO231220-11

Heat No	C	Mn	P	S	Si	Al	Cu	Cb	Mo	Ni	Cr	V	Ti	B	N	Ca
NL6292	0.190	0.850	0.007	0.001	0.035	0.033	0.120	0.001	0.010	0.080	0.050	0.004	0.001	0.0000	0.0060	0.0020

Bundle No M400201232 **PCs** 24 **Yield** 068248 Psi **Tensile** 083057 Psi **Eln.2in** 27 % **Certification** ASTM A500-21 GRADE B&C **CE: 0.36**

Heat	MILL	Mill Location	Method	Recycled Content	Post Consumer	Pre-Consumer (Post Industrial)	% Harvested	Within Miles of Location
NL6292	NUCOR	Decatur,AL	EAF	53.70%	23.80%	29.90%	86%	500

Material Note:
Sales Or. Note:

Authorized by Quality Assurance *Jason Richard*
Jason Richard

The results reported on this report represent the actual attributes of the material furnished and indicate full compliance with all applicable specification and contract requirements. CE calculated using the AWS D1.1 method. This document is in compliance with the requirements of EN 10204 type 3.1

