

Atlas Tube Alabama
 171 Cleage Dr
 Birmingham Alabama USA
 35217
 Tel:
 Fax:

Atlas Tube
 A DIVISION OF ZEKELMAN INDUSTRIES

REF.B/L: 81172824
 Date: 09/11/2023
 Customer: 1592

Sold To

Superior Supply and Steel
 PO Box 2388
 SULPHUR LA 70664
 USA

MATERIAL TEST REPORT

Shipped To

Superior Supply and Steel
 318 North Cities Service Hwy
 SULPHUR LA 70663
 USA

Material: 2.0x2.0x250x20"0(6x6) Material No: 0200202502000-B Made in: USA
 Melted and Poured in: USA

Sales Order: 1950801 Purchase Order: P0243801-01 Cust Material#: 982024310 CE: 0.28

Heat No	C	Mn	P	S	Si	Al	Cu	Cb	Mo	Ni	Cr	V	Ti	B	N	Ca
SN4062	0.190	0.370	0.009	0.003	0.025	0.028	0.130	0.000	0.010	0.030	0.070	0.001	0.002	0.0000	0.0050	0.0010
Bundle No	PCs	Yield	Tensile	Eln.2in	Certification											
MC00215270	36	061711 Psi	071601 Psi	30.6 %	ASTM A500-21 GRADE B&C											
Heat	MILL	Mill Location	Method	Recycled Content	Post Consumer	Pre-Consumer (Post Industrial)	% Harvested	Within Miles of Location								
SN4062	NUCOR	Decatur,AL	EAF	53.70%	23.80%	29.90%	86%	500								

Material Note: Material No: 0250251882000-B Made in: USA
 Melted and Poured in: USA
 Cust Material#: 982024330

Material: 2.5x2.5x188x20"0(5x5) Purchase Order: P0243801-01

Heat No	C	Mn	P	S	Si	Al	Cu	Cb	Mo	Ni	Cr	V	Ti	B	N	Ca
B305144	0.210	0.450	0.013	0.004	0.020	0.024	0.090	0.000	0.010	0.030	0.040	0.001	0.001	0.0001	0.0071	0.0020
Bundle No	PCs	Yield	Tensile	Eln.2in	Certification											
MC00213251	25	062122 Psi	080850 Psi	25.6 %	ASTM A500-21 GRADE B&C											
Heat	MILL	Mill Location	Method	Recycled Content	Post Consumer	Pre-Consumer (Post Industrial)	% Harvested	Within Miles of Location								
B305144	SDI	Columbus,MS	EAF	76.00%	95.00%	5.00 %	75%	500								

Material Note: Sales Or. Note:

Authorized by Quality Assurance *Jason Richard*

The results reported on this report represent the actual attributes of the material furnished and indicate full compliance with all applicable specification and contract requirements. CE calculated using the AWS D1.1 method. Steel is purchased fully killed with a fine grain practice. This document is in compliance with the requirements of EN10204 type3.1

