

**Mill Certification**

03/28/2025

MTR#:1940668-8  
 Lot #:110006412862  
 8812 HWY 79 W  
 Jewett, TX 75846 US  
 903 626-4461  
 Fax: 903 626-6290

Sold To: SUPERIOR SUPPLY & STEEL  
 PO BOX 2388  
 SULPHUR, LA 70664 US

Ship To: SUPERIOR SUPPLY  
 318 CITIES SERVICE HWY  
 HWY-108  
 SULPHUR, LA 70663 US

Customer PO	P0255728-01	Sales Order #	11084200 - 5.1
Product Group	Hot Roll - Merchant Bar Quality	Product #	2027159
Grade	Nucor Multigrade	Lot #	110006412862
Size	5" x 3" x 0.25"	Heat #	1100064128
BOL #	BOL-1981518	Load #	1940668
Description	Hot Roll - Merchant Bar Quality Unequal Angle 5" x 3" x 1/4" Nucor Multigrade 20' 0" [240"] 2001-6000 lbs	Customer Part #	
Production Date	03/07/2025	Qty Shipped LBS	5016
Product Country Of Origin	United States	Qty Shipped EA	38
Original Item Description		Original Item Number	

I hereby certify that the material described herein has been manufactured in accordance with the specifications and standards listed above and that it satisfies those requirements.

Melt Country of Origin : United States

Melting Date: 12/04/2024

Roll Country of Origin : United States

Rolling Date: 12/30/2024

C (%)	Mn (%)	P (%)	S (%)	Si (%)	Ni (%)	Cr (%)	Mo (%)	Cu (%)	Ti (%)	V (%)	Nb (%)
0.14	0.80	0.015	0.014	0.204	0.13	0.21	0.04	0.26	0.001	0.036	0.001
Sn (%)											
0.009											

ASTM A529 S78.2 CE (%) : 0.39

**Tensile testing**

	Yield (PSI)	Tensile (PSI)	Elongation in 8" (%)
(1)	57900	73800	22.0
(2)	59200	75700	22.0

**Comments:**

NUCOR MULTIGRADE MEETS THE REQUIREMENTS OF: ASTM A36/A36M-14; A529/529M-05(2009) GR50(345); A572/572M-07 GR50(345); A709/709M-10 GR36(250) & GR50(345); CSA G40.21-04 GR44W(300W)& GR50W(350W); AASHTO M270/M270M-10 GR36(270) & GR50(345); ASME SA36/SA36M-07; MEETS REPORTING REQUIREMENTS OF EN10204 SEC 3.1

1. All manufacturing processes of the steel, including melting, casting & hot rolling, have been performed in U.S.A
2. Mercury not intentionally added at any point during manufacturing or testing of this material.
3. Welding or weld repair was not performed on this material.
4. This material conforms to the specifications described on this document and may not be reproduced, except in full, without written approval of Nucor Corporation.
5. Results reported ASTM E45 (Inclusion content) and ASTM E381 (Macro-etch) are provided as interpretation of ASTM procedures.



Ramon Vigil, Quality Supervisor