

Atlas Tube Alabama
 171 Cleage Dr
 Birmingham Alabama USA
 35217
 Tel:
 Fax:



REF.B/L: 81191733
 Date: 12/19/2023
 Customer: 179

MATERIAL TEST REPORT

Sold To

Shipped To

1000
 MANHATTAN KS 66505
 USA

2000
 LONGVIEW TX 75604
 USA

Material:	5.0x3.0x250x20'0"(22x1)PB										Material No:	50030250		Made in:	USA	
Sales Order:	1989476										Purchase Order:	4500565228		Melted and Poured in:	USA	
Heat No	C	Mn	P	S	Si	Al	Cu	Cb	Mo	Ni	Cr	V	Ti	B	N	Ca
W66527G23	0.190	0.720	0.012	0.011	0.013	0.045	0.040	0.005	0.004	0.020	0.050	0.002	0.001	0.0001	0.0050	0.0000
Bundling No	PCs	Yield	Tensile	Eln 2in		Certification						CE: 0.33				
M801171284	22	066448 Psi	077435 Psi	32.4 %		ASTM A500-21 GRADE B&C										
Heat	MILL	Mill Location	Method	Recycled Content	Post Consumer	Pre-Consumer (Post Industrial)	% Harvested	Within Miles of Location								
W66527G23	USSTEEL	GARY, IN	BOF	34.20%	19.80%	14.40%	100%	500								
Material Note:																
Sales Or. Note:																

Authorized by Quality Assurance: *Jason Richard*
Jason Richard

The results reported on this report represent the actual attributes of the material furnished and indicate full compliance with all applicable specification and contract requirements. CE calculated using the AWS D1.1 method. Steel is purchased fully killed with a fine grain practice. This document is in compliance with the requirements of EN10204 type3.1

