



CERTIFIED MATERIAL TEST REPORT

US-ML-MIDLOTHIAN
300 WARD ROAD
MIDLOTHIAN, TX 76065
USA

Table with customer information: CUSTOMER SHIP TO, CUSTOMER BILL TO, GRADE (A992/A572-50), SHAPE / SIZE (Wide Flange Beam / 14 X 48# / 360 X 72), DOCUMENT ID (0001157036), LENGTH (40'00"), PCS (4), WEIGHT (7,680 LB), HEAT / BATCH (58062496/05), SALES ORDER (14356485/000010), CUSTOMER MATERIAL N° (000000003714480040), SPECIFICATION / DATE or REVISION (ASTM A6-24A, ASTM A709-21 GR50, ASTM A992-22, A572-21E1, CSA G40.21-13(R23) 345WM, 50W), CUSTOMER PURCHASE ORDER NUMBER (G450044726), BILL OF LADING (1327-0000596396), DATE (09/23/2024).

CHEMICAL COMPOSITION table with columns: C (%), Mn (%), P (%), S (%), Si (%), Cu (%), Ni (%), Cr (%), Mo(%), Sn (%), V (%), Nb (%), CEqvA6 (%). Values: C (0.07), Mn (1.05), P (0.018), S (0.030), Si (0.18), Cu (0.25), Ni (0.10), Cr (0.32), Mo (0.033), Sn (0.008), V (0.007), Nb (0.019), CEqvA6 (0.34).

MECHANICAL PROPERTIES table with columns: YS 0.2% (PSI), UTS (PSI), YS (MPa), UTS (MPa), Y/T rati (%), G/L (Inches), G/L (mm), Elong. (%). Values: YS 0.2% (54910, 54121), UTS (70356, 69224), YS (379, 373), UTS (485, 477), Y/T rati (0.780, 0.780), G/L (8.000, 8.000), G/L (200.0, 200.0), Elong. (25.40, 24.90).

COMMENTS / NOTES
Gerdaus steel is 100% recyclable. Support the circular economy through our Metals Recycling Partnership. For details, visit www2.gerdau.com/metals-recycling, or contact metalsrecycling@gerdau.com.

The above figures are certified chemical and physical test records as contained in the permanent records of the company. We certify that these data are correct and in compliance with specified requirements. No weld repair was performed on this material. The material has not been in contact with mercury while in Gerdaus possession. For all products other than billets or beam blanks, this material was produced (Electric Arc Furnace, Melted, Continuously Cast, Hot Rolled and, if applicable, Cold-Drawn) in the USA. For billets or beam blanks, this material was produced (Electric Arc Furnace, Melted and Continuously Cast) in the USA. CMTR complies with EN 10204 3.1.

Bhaskar Yalamanchili
BHASKAR YALAMANCHILI
QUALITY DIRECTOR

Wade Lumpkins
WADE LUMPKINS
QUALITY ASSURANCE MGR.

Phone: (409) 267-1071 Email: Bhaskar.Yalamanchili@gerdau.com

Phone: 972-779-3118 Email: Wade.Lumpkins@gerdau.com